Biomass Thermal Heating at California Conservation Camps & Elsewhere



TSS Consultants – January 2017



Fuel Cost Comparisons

Energy Type	Current Price		Energ	y Content		per Unit nergy	System Efficiency	All-In Price per Unit Energy			
Propane	2.10	\$/gal	91,500	Btu/gal	22.951	\$/MMBtu	0.80	28.693	\$/MMBtu		
Propane	2.65	\$/gal	91,500 Btu/gal		28.962	\$/MMBtu	0.80	36.208	\$/MMBtu		
Natural Gas*	0.775	\$/Therm	100,000	Btu/Therm	7.754	\$/MMBtu	0.80	9.692	\$/MMBtu		
Electricity @ 12¢	0.12	\$/kWh	3,412	Btu/kWh	35.170	\$/MMBtu	0.98	35.888	\$/MMBtu		
Electricity @ 17¢	0.17	\$/kWh	3,412	Btu/kWh	49.824	\$/MMBtu	0.98	50.841	\$/MMBtu		
Woody Biomass											
Feedstock	35	\$/BDT	8,500	Btu/lb	2.059	\$/MMBtu	0.70	2.941	\$/MMBtu		
Woody Biomass Feedstock	60	\$/BDT	8,500	Btu/lb	3.529	\$/MMBtu	0.70	5.042	\$/MMBtu		

California Conservation Camps CALFIRE and Department of Corrections








Conservation Camp Locations

There are 44 conservation camps in California in or adjacent to forested lands. Thirty-nine of the camps are jointly managed by CalFire and the Dept. of Corrections






BIOMASS HEATING CONSERVATION CAMP DEVILS GARDEN




AERIAL VIEW







DGCC System Description


- Boiler sized at 1.75 MMBTU/hour heating input
- Boiler building approximately 30 by 40 feet (includes fuel bin)
- Approximately 1,679 feet of hot water distribution piping
- Cyclone separator to control particulate matter











BIOMASS HEATING CONSERVATION CAMP TRINITY RIVER



Weaverville Lewiston Douglas City


AFRIAL MEY





TRCC System Description

- Boiler sized at 1.75 MMBTU/hour heating input
- Boiler building approximately 30 by 40 feet (includes fuel bin)
- Approximately 1,356 feet of hot water distribution piping
- Cyclone separator to control particulate matter









Devil's Garden Energy User New System List

TSS20471

Conservation Camp Biomass Heating

Devil's Garder	n Energy User List						
	Building	Description					
1	A/BOQ	Admin, Headquarters					
2	м	Mess, Dining Hall					
3	D/R/L	Dorms, Recreation, Laundry					
4	H/W	Gym, Weights					
5	PS/W	Wood Shop, Garage, etc.,					
6	VE	Vehicle, equipment					
7	F/G	Fuel, Generator					
8	FV	Family Visitor Housing					

Loop	Output MBh
Loop 1	1,195
Loop 2	1,557
Total	2,752

ID#	Drawing	BLDG	Туре	Model	HHV Output	Recovery Rate	Piping Loop	Piping Connection Size
	Schematic					Gal/hr		Dia (in)
UH-1	280-003	A/BOQ	Upflow		71		Loop 2	
UH-2	280-003	A/BOQ	Air heater		91		Loop 2	
UH-3	280-004	A/BOQ	Air heater		661		Loop 2	
UH-4	280-005	A/BOQ	Air heater		71		Loop 1	
UH-5	280-006	A/BOQ	Air heater		71		Loop 1	
UH-6	280-007	A/BOQ	Air heater		37		Loop 1	
UH-7	280-008	A/BOQ	Air heater		37		Loop 1	
UH-8	280-009	A/BOQ	Air heater		71		Loop 1	
UH-9	280-010	A/BOQ	Air heater		71		Loop 1	
UH-10	280-011	A/BOQ	Air heater		71		Loop 1	
UH-11	280-012	A/BOQ	Air heater		53		Loop 1	
UH-12	280-013	A/BOQ	Radiant		20		Loop 1	
UH-13	280-014	A/BOQ	Radiant		80		Loop 1	
UH-14	280-015	A/BOQ	Radiant		80		Loop 1	
UH-15	280-016	A/BOQ	Radiant		80		Loop 1	
UH-16	280-017	A/BOQ	Radiant		56		Loop 1	
UH-17	280-018	A/BOQ	Radiant		80		Loop 2	
UH-18	280-019	A/BOQ	Radiant		80		Loop 2	
UH-19	280-020	A/BOQ	Radiant		80		Loop 2	
UH-20	280-021	A/BOQ	Radiant		80		Loop 2	
UH-21	280-022	A/BOQ	Wood Stove		-		Loop 2	
UH-22	280-023	A/BOQ	Radiant		20		Loop 2	
UH-23	280-024	A/BOQ	Radiant		80		Loop 2	
UH-24	280-025	A/BOQ	Radiant		56		Loop 2	
UH-25	280-026	A/BOQ	Unit Heater		44		Loop 2	
UH-26	280-027	A/BOQ	Air heater		33		Loop 2	
WH-1	280-028	A/BOQ	Water Heater		145	193	Loop 2	
WH-2	280-029	A/BOQ	Water Heater		145	193	Loop 1	
WH-3	280-030	A/BOQ	Water Heater		145	193	Loop 1	
WH-4	280-031	A/BOQ	Water Heater		51	68	Loop 1	
WH-5	280-032	A/BOQ	Water Heater		51	68	Loop 1	
WH-6	280-033	A/BOQ	Water Heater		6	7	Loop 1	
WH-7	280-034	A/BOQ	Water Heater		36	60	LOOD 2	



Installation Cost Estimate - Devils Garden TSS20471 Conservation Camp Biomass Heating

Biomass boiler costs:		
boiler	\$184,063.95	
fuel system	\$ 81,375.00	
building/enclosure	\$ 46,095.00	
Subtotal		\$ 311,533.95
District Heat system cost		
Building Conversion	\$ 66,804.00	
Piping cost	\$ 76,171.10	
Thermal Storage	\$ 26,250.00	
Subtotal		\$ 169,225.10
Installation		
Mechanical	\$ 75,309.68	
Mechanical - Piping	\$ 64,368.68	
Electrical	\$ 29,792.06	
Civil	\$ 5,197.50	
Subtotal		\$ 174,667.91
Project Management & Misc		
Project Management	\$93,715	
Subtotal		\$ 93,715.19
Engineering		
Engineering	\$39,488	
Subtotal		\$ 39,487.86
Contingency		\$78,863
TOTĂL		\$ 867,493.01
		-





Wood Chip Boiler Devil's Garden Conservation Camp Alturas, CA 6/20/2016 Fuel costs Wood Cost REV A Propane Cost Electricity Debt Service Units MMBTU MMBTU KWH Total installation cost 3.48 \$ 0.07 \$ 867,493.01 Cost per unit \$ 15.72 \$ Escalation rate Grants 6% 3% \$ 20.27 Total Project Cost \$ 867,493.01 O&M Costs - Wood O&M Costs, Exist labor labor 2.50 2.50 Labor (Hr/ wk) Labor (Hr/ wk) \$/hr \$ 25.00 \$/hr \$ 25.00 Wk/Yr 40.00 Wk/ Yr 40.00 Total/ Yr \$ 2,500.00 Total/ Yr \$ 2,500.00 Annual increase 2% Annual increase 2% Cost Comparison Year 1 Year 2 Year 3 Year 4 Year 5 Year 6 Year 7 Year 8 Year 9 Year 10 Year 15 Existing heating system operating costs 74,732 \$ 83,969 \$ 89,007 \$ 94,348 \$ 100,009 \$ 112,370 \$ 79,216 \$ 106,009 \$ 119,112 \$ 126,259 \$ 168,963 \$ Propane Cost \$ Electric cost - \$ 5 5 S \$ 2,653 \$ S S \$ S 2,760 \$ 2,815 \$ 2,929 \$ 2,988 \$ 2,601 \$ 2,872 \$ 2,500 \$ 2,550 \$ 3,299 \$ O&M cost Total 77,232 \$ 81,766 \$ 86,570 \$ 91,660 \$ 97,054 \$ 102,769 \$ 108,825 \$ 115,241 \$ 122,041 \$ 129,246 \$ 172,261 \$ \$ Proposed heating system operating costs 3,961 \$ 16,163 \$ 4,198 \$ 4,450 \$ 17,147 \$ 4,717 \$ 17,662 \$ 5,300 \$ 18,737 \$ 5,618 \$ 19,300 \$ 5,956 \$ 19,879 \$ 6,313 \$ 8,448 \$ 23,736 \$ 3,737 \$ 5,000 \$ Propane Cost \$ Woood cost 15,692 \$ 16,648 \$ 18,192 \$ 20,475 \$

O&M cost	\$ 2,500	\$	2,550	\$	2,601	\$	2,653	5	2,706	\$	2,760	\$	2,815	\$	2,872	\$	2,929	\$	2,988	\$	3,299	\$	3,642
Total	\$ 21,929	\$	22,674	\$	23,447	\$	24,251	S	25,085	S	25,952	S	26,853	S	27,790	S	28,763	S	29,776	\$	35,483	\$	42,464
Yearly operational savings	\$ 55,303	\$	59,092	s	63,123	5	67,410	s	71,969	s	76,817	s	81,971	\$	87,452	s	93,278	s	99,471	s	136,778	s	187,288
Total savings	\$ 55,303	\$	114,396	\$	177,518	\$	244,928	5	316,897	S	393,713	S	475,684	5	563,136	s	656,414	5	755,885	5	1,360,633	\$	2,189,959
Investment	\$ 867,493.01																						
Annual cash flow	\$ 55,303	\$	59,092	S	63,123	S	67,410	S	71,969	S	76,817	S	81,971	S	87,452	S	93,278	S	99,471	S	136,778	S	187,288
Cummulative cash flow	\$ (812,190)	5	(753,097)	\$	(689,975)	5	(622,565)	S	(550,596)	S	(473,780)	S	(391,809)	\$	(304,357)	S	(211,079)	\$	(111,608)	\$	493,140	5	1,322,466

Devil's Garden CC

Heating Season	Propane Usage	Propane Cost	Propane Cost
internation (1993)	*gal/yr	\$/yr	\$/gal
2013/2014	66,388.77	\$123,321.95	\$ 1.86
2014/2015	62,636.01	\$71,697.59	\$ 1.14
2015/2016	65,929.06	\$65,929.06	\$1.00
*Amounts are estimated from annual Involces			

**2013/2014 Amounts uncharacteristically high.

a Re

Year 20

226,110

229,752


11,306

27,517


3,642



SCHEMATICS



 The pump is controlled by the WoodMaster Control (standard) · Variable pump speed based on boiler temp and deltaT



 When the boiler pump is satisfied, BTU can be delivered to load, or thermal storage/buffer tank. · Pump modulates to load requirements, based on boiler temp and deltaT

* These are generic diagrams for informational purposes only.

Building Installs



Government Office Buildings Yellowknife, NWT 2,217 MBH



Sussex Elementary School Sussex, New Brunswick 1,364 MBH



Wolf Ridge Environmental Learning Center Finland, MN 3.240 MBH



Anna Marta College Paxton, MA 5,629 MBH



Iron, MN









Minnesota Dept. of Natural Resources Tower, MN 440 MBH

EXAMPLES OF SYSTEMS IN OPERATION

affordability.

WOOD PELLETS

· Fully automatic and reliable

 Most efficient BTU use · Higher price per ton · Require least amount of handling

PREMIUM CHIPS

. Al or A2 - P16

· 35% moisture content or less

· Reliable heating and consistent size

oNorm M7 133 (50, W30 (chip spec)

-based on CAN/CSA-150 177225

(matchbook size chips) Require slightly more handling than pellets

FIND YOUR FUEL TYPE

What type of fuel is best for your system? That depends on a range of factors, including availability, the

amount of handling necessary and

· Consistent moisture content-10% or less

Heat Cabin Installs



Cherry School



Arrowhead Regional Corrections Facility-NERCC- Saginaw, MN 4,435 MBH








Minden, NV 2,729 MBH



Hungry Mothers Organic








Boiler Systems









Pre-Configured Insulated Pipe





Heat Transfer









Permitting

- Modoc County Air Pollution Control District
 - Rule 2.2 allows for an exemption of boilers under 5 MMBTU per hour no permit needed!
- North Coast Unified Air Quality Management District
 - Rule 102 exempts boilers 1 MMBTU per hour or lower ATC will be needed
- Both facilities will require some CEQA and NEPA review



Other TSS Biomass Thermal Projects

• Mono County Maintenance Facility





• Sierra at Tahoe Ski Resort





Other TSS Biomass Thermal Projects (cont'd)

• Taos Region Biomass Heating



• Sierra Nevada Conservancy Small-Scale Boiler Survey

Air District	County	Town	Building/ Permittee	Fuel Source	MMBtu/h size class	MMBtu/h
			County			Not
Modoc	Modoc	Alturas	Courthouse	Kerosene	1 to 5	specified
			Tuolumne			
			General			
			Medical	Diesel		
Tuolumne	Tuolumne	Sonora	Facility	(No. 2)	1 to 5	1.843
			Butte-Glenn			
			Community			
Butte	Butte	Oroville	College	Nat Gas	1 to 5	1.2





For Further Information

Frederick Tornatore TSS Consultants

fatoxic@tssconsultants.com 916.601.0531 www.tssconsultants.com

